



天津匡宝天辰能源设备技术咨询服务有限公司
Tianjin Campbell TCC Energy Technical Consulting Services Co., Ltd.
会议纪要
MUNITES OF MEETING

项目名称 Project Name	T16B05 Gardabani II Combined Cycle Power Plant Project	会议纪要编号 MOM No.	CAPTCC-CT18008036-IR004-MOM
客户 Client	中国天辰工程有限公司 China Tianchen Engineering Corporation	客户订单号 Client P.O. No.	BP-T16B05-EQU-EH-18011
检验通知号 Reference No.	P-T16B05-EQU-EH-18011-PC14-IN05-Rev.B	检验员 Inspector	Wu Lianzhong
制造商 Vendor	Jiangsu sieyuan hertz instrument transformer Co.,ltd	检验地址 Inspection Location	No.5, West Huimin Road, Rugao, Jiangsu Province P.R.China
分包商 Sub-Vendor	N/A	检验日期 Visit Date(s)	2 nd , 3 rd , 4 th . July, 2019

本次检验参与人员 THE PARTICIPANTS OF THIS VISIT			
姓名 NAME	公司 COMPANY	代表方 REPRESENTING	联系方式 CONTACT NO.
Mr. Wu Lianzhong	Inspector	TCC	13813143133
Dai Bingbing	Inspection coordinate	Sieyuan hertz	18862779910

本次检验产品 MATERIAL/ SUBJECT OF INSPECTION	编号 Code No.	订单数量 QTY as per P/O	所检数量 QTY offered for inspection
Current Transformer	11192888	1 SET	1 SET
Total:			

结论 CONCLUSION
<p>During this visit, TCC inspector carried out the inspection activities as per notification witness point and approved ITP with acceptable result, the details refer as below descriptions:</p> <ol style="list-style-type: none"> 1. Design and visual checks -ITP STEP B1 2. Power-frequency withstand test on secondary windings - ITP STEP B1 3. Power-Frequency Withstand Test on Primary Windings - ITP STEP B1 4. Partial Discharge Measurement - ITP STEP B1 5. Measurement of Capacitance & Dielectric dissipation Factor Test -ITP STEP B1 6. Inter-Turn Overvoltage Test -ITP STEP B1 7. Measuring of DC Resistance of secondary windings -ITP STEP B1 8. Error Determination -ITP STEP B1 9. Test for rated knee point e.m.f. and exciting current at rated knee point e.m.f -ITP STEP B1 10. Packing inspection 11. Document



天津匡宝天辰能源设备技术咨询服务有限公司
Tianjin Campbell TCC Energy Technical Consulting Services Co., Ltd.
会议纪要
MUNITES OF MEETING

Remark: Oil leakage test-ITP STEP B1, Due to the oil leakage test is process test and can't be test during the final test stage, inspector only reviewed the test record and found that is acceptable.

A handwritten signature in black ink, appearing to read 'William Hoag'.

TCC:

Signature: 4. July, 2019

Vendor:

Signature :

A handwritten signature in black ink, appearing to be Chinese characters '穆海荣'.

结束
End of Report